

消 防 處
牌 照 及 審 批 總 區
香 港 九 龍 尖 沙 咀 東 康 莊 道 1 號 5 樓
消 防 總 部 大 廈



FIRE SERVICES DEPARTMENT
LICENSING AND CERTIFICATION COMMAND
5/F, FIRE SERVICES HEADQUARTERS BUILDING,
No.1 Hong Chong Road, Tsim Sha Tsui East,
Kowloon, Hong Kong.

本處檔號 OUR REF.: (29) in FP/207/1005(II)
個案編號 LIFIPS No.: 566105
來函檔號 YOUR REF.:
電子郵件 E-mail: lcpolice2@hkfsd.gov.hk
圖文傳真 FAX: (852) 2367 3631
電 話 TEL NO.: (852) 2733 7605

16 August 2018

Delta Pyramax Co., Ltd.
4/F, Maxwell Industrial Building,
350 Kwun Tong Road,
Kwun Tong, Hong Kong

Dear Sirs,

**Application for Acceptance of
Viega Press Fitting**

I refer to my interim reply of 20 April 2017 on the captioned subject.

Please be informed that according to the FSD Circular Letter No. 1/2007, captioned equipment is not on the list of "Fire Service Installations and Equipment Requiring FSD Approval" and therefore application for its prior acceptance by this Department is not required. Please refer to the following website for more information:-

http://www.hkfsd.gov.hk/home/eng/source/circular/2007_01.pdf

Please feel free to call Senior Station Officer CHAN Sze-chit at 2733 7827 for any other questions.

Yours faithfully,

(YEUNG Lap-sun)
for Director of Fire Services

YLS/csc